

MALAYSIAN STANDARD

MS 1073 : Part 3 : 1996

SPECIFICATION FOR FIRE RESISTANT DOORSETS PART 3: METHODS FOR DETERMINATION OF THE FIRE RESISTANCE- TYPE OF DOORSETS

The attached amendment on MS 1073: Part 3:1996 has been formally approved by the Technical Committee on Fire Properties for Building Materials.

Date: 11 Mac 2003
Amd. 1

(1) Page 20, Appendix B, Clause B2, line 1

To delete the following:

'of 1000 mm (width) x 2100 mm (height)'.

(2) Page 20, Appendix B, Clause B3.2, line 3

To replace 'an opening of not less than 75 degrees' with 'an opening of not less than 85 degrees'

(3) Clause B3.3 and Clause 3.4 shall be renumbered as Clause B3.4 and B3.5 respectively.

(4) Clause B3.3, to replace the original sentence with the following:

'The power size of the door closer for test specimen shall follow Table 1 below'.

(5) Clause B3.4, to replace the original sentence with the following:

'The latchbolt of the specimen doorset shall be held in its original position throughout the cyclic test, for the purpose of checking that the doorset closes and latches properly'.

MS 1073 : Part 3 : 1996

Amd. 1
Page 1 of 1